

March 3, 2010

**VIA ELECTRONIC FILING**

Ms. Jocelyn Boyd  
Interim Chief Clerk/Administrator  
Public Service Commission of South Carolina  
Post Office Drawer 11649  
Columbia, SC 29211

**Re: Duke Energy Carolinas, LLC – Docket No. 2009-404-E**  
Revised Report – Original Report filed March 1, 2010  
Non-Employee Electrical Contact  
Fatality: Chang B. Yang and Toua Yang  
Date of Accident: February 28, 2010


Dear Ms. Boyd:

On behalf of Duke Energy Carolinas, we are filing this revised report of the Yang accident. This is to advise that Mr. Chang B. Yang, age 49 and his son, Tuoa Yang, age 28, of 375 Canaan Road, Spartanburg, South Carolina, 29306 were fatally injured from an electrical contact that occurred on February 28, 2010. Our initial report indicates that the father and son were attempting to move a 37 foot aluminum ladder to trim a large oak tree when it made contact with a 7200 volt Duke Energy distribution line.

Spartanburg County Coroner Rusty Clevenger investigated the accident. Duke Energy's investigation is continuing on the matter. The original report filed on March 1<sup>st</sup> incorrectly indicated that contact was made with a "7200KV" instead of "7200 volt" distribution line. Should you desire any additional information, please contact me.

Very truly yours,

ROBINSON, MCFADDEN & MOORE, P.C.



Bonnie D. Shealy

/bds

cc: Florence Belser, ORS General Counsel (via email)  
Lara Nichols, Associate General Counsel (via email)

**Bonnie D. Shealy**  
1901 MAIN STREET, SUITE 1200  
POST OFFICE BOX 944  
COLUMBIA, SOUTH CAROLINA 29202  
**PH**  
(803) 779-8900 | (803) 227-1102 *direct*  
**FAX**  
(803) 252-0724 | (803) 744-1551 *direct*  
bshealy@robinsonlaw.com